

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF DEXTER-ALMO HEIGHTS)	
WATER DISTRICT FOR A DEVIATION PURSUANT)	CASE NO.
TO 807 KAR 5:066, SECTION 4(4), REGARDING)	94-011
WATER STORAGE)	

O R D E R

On January 7, 1994, the Dexter-Almo Heights Water District ("Dexter-Almo") filed an application for a deviation from Commission Regulation 807 KAR 5:066, Section 4(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. On January 7, 1991, the Commission granted Dexter-Almo a deviation from this requirement in Case No. 91-399.¹ That deviation was based on a letter from the City of Murray Public Works and Utilities ("City of Murray") which stated that the City of Murray would provide Dexter-Almo's needed storage until September 24, 1994.

On January 24, 1994, Dexter-Almo filed a letter from the City of Murray which stated that it would provide Dexter-Almo's needed storage from its 3.75 million gallons of storage capacity until January 4, 1997.

¹ Case No. 91-399, The Application of Dexter-Almo Heights Water District for a Deviation Pursuant to 807 KAR 5:066, Section 5(4), Regarding Water Storage. The storage required by the Regulation has remained the same since 1991, but the reference has changed from Section 5(4) of 807 KAR 5:066 to Section 4(4).

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Dexter-Almo has no water storage tanks in its distribution system.


2. Dexter-Almo's average daily water usage is approximately 69,000 gallons per day.


3. The City of Murray is willing to provide Dexter-Almo with needed storage capacity for the next three years.


IT IS THEREFORE ORDERED that Dexter-Almo be and it hereby is granted a deviation from the water storage requirements of 807 KAR 5:066, Section 4(4), for so long as its agreement with the City of Murray remains in effect, but no later than January 1, 1997.

Done at Frankfort, Kentucky, this 11th day of March, 1994.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director